

Bruneau-Grand View Joint School District #365

NONINSTRUCTIONAL OPERATIONS

8300P8

Natural Gas Leak

In the event a natural gas leak is discovered or suspected:

1. Turn off the gas valve serving the building or area;
2. Open windows and doors to dissipate the fumes; and
3. The building principal should evacuate the building by the most appropriate means.

The public utilities company and local fire department shall be notified by the secretary, principal, or any person aware of the emergency.

Note: Do not assume that these public utilities and the local fire department have been notified. It is preferred that several people notify them rather than run the risk of complete omission.

Procedure History:

Promulgated on:

Revised on:

Reviewed on: